

BIOSAFETY LEVEL 2/3 FACILITY REQUIREMENTS

Office of Health and Safety

CDC
Centers for Disease Control
and Prevention

Laboratories Protect

- **Personnel**
Scientists, technicians, maintenance workers
Custodial workers, visitors, students
- **Products**
Samples, reagents, processes
- **Environment**
Adjacent non-laboratory areas, other laboratories
The community, exterior environment



Office of Health and Safety


CDC
Centers for Disease Control
and Prevention


Laboratory Hazards


- **Chemical**
Flammables, acids, corrosives, reactive chemicals, carcinogens
Mutagens, teratogens, toxins, compressed gases
- **Radiological**
Radionuclides, equipment that produces ionizing radiation
- **Physical**
Lasers, magnet fields, moving parts, high voltage, high noise
ultraviolet light, extreme heat or cold
- **Biological**
Etiologic agents, material containing etiologic agents
Organisms with recombinant DNA, toxins, allergens


Office of Health and Safety


CDC
Centers for Disease Control
and Prevention














Biological Laboratory Ventilation

- Sealing the Barrier

- Building Component Movement
- Sealant Failure
- Penetration Control
- Ducts, pipes, vents and conduits
- Doors, door seals
- Dynamic Conditions

Office of Health and Safety


CDC
Centers for Disease Control
and Prevention

Biological Laboratory Ventilation

- Ante Room

CORRIDOR

SUGGESTED
(50-100 CFM)



Office of Health and Safety

CDC
Centers for Disease Control
and Prevention

CDC Infectious Diseases Laboratory

Technical Criteria BSL3


- HVAC

- Inward directional airflow
- 10 air change minimum
- Manifoldd exhaust
- Non filtered exhaust
- Thimble connected BSC

Office of Health and Safety

CDC
Centers for Disease Control
and Prevention

BSL3 Suite



Office of Health and Safety

CDC
Centers for Disease Control
and Prevention
